

## **LARGE METER CHECKLIST**

1. THERE IS AT LEAST 8" OF THICK GRAVEL IN BOTTOM OF METER BOX WITH AT LEAST 12" OF CLEARANCE BETWEEN GRAVEL AND BOTTOM OF VALVE.
2. THERE IS A DRESSER OR A FLANGED COUPLING ADAPTER ON HOUSE SIDE OF METER AND ON HOUSE SIDE OF BY-PASS VALVE.
3. THERE ARE AT LEAST THREE VALVES IN METER BOX TO REGULATE WATER THROUGH METER AND BY-PASS.
4. BY-PASS IS OFF AND SEALED.
5. METER IS INSTALLED IN THE CORRECT DIRECTION.
6. 30" HEAVY DUTY RING & COVER.
7. THERE IS AT LEAST 6" OF CLEARANCE MINIMUM BETWEEN WALL OF METER BOX AND NEAREST FLANGES.
8. PIPELINES OUTSIDE OF THE METER BOX MUST BE RESTRAINED EITHER TO THE NEXT JOINT OR WITH A 2'x2'x1/4" STEEL PLATE BUTTED AGAINST THE OUTSIDE OF THE WALL WITH A MEGULUG AGAINST THE PLATE.