



Purchasing Division

REQUEST FOR PROPOSAL: Lindquist Field Lighting

ADDENDUM NO. 2

DATE: October 1, 2019

This addendum is issued to modify the previously issued bid documents and/or given for informational purposes, and is hereby made part of the bid document. Please acknowledge receipt by printing and signing this document and include with your proposal.

Q&A:

1. You mentioned the desire to have "different scenes." Can you please expound on that?
 - a. Yes, we would like a system that has the options to provide "different scenes lighting." For example, if there is a home-run, if we push this button /option, a different lighting effect will showcase the home-run.
2. Can you extend the bid deadline?
 - a. This question has been addressed in addendum 1.
3. Do you have as-builts or drawings that we can review for structural and/or electrical details?
 - a. This question has been addressed in addendum 1.
4. Minimum Lumen Output of 13,700,000 - Where did you get that number? Seems to be very specific? Our company can output the entire field with under 10,000,000.
 - a. As you know, our team does not specialize on this and we do not do this every day. We looked at different sources to come up with the technical aspects.
 - b. Please provide the overall lumen output for the entire field lighting system of your design that accomplishes the standard of 100/70 foot-candles with the above stated uniformity requirements.
5. Light Level Average of 40-ft Candles - What tools are you measuring CANDELA?
 - a. Candela requirement has been removed.
 - b. Please provide the light levels measured in foot-candles that will be achieved at the 16 locations noted on the attached map, and to what parameters these levels can be adjusted without affecting the standard of 100/70 foot-candles on the playing field.
6. Dark Sky Requirements
 - a. We have a neighboring City that is very particular with light pollution. Ogden City is not looking for a Dark Sky Friendly certificate for your fixtures. We want to know how your design may address Dark Sky parameters while attaining the specified lighting levels.



Purchasing Division

7. 25 Year Warranty Requirement:
 - a. Provide details on your best warranty for onsite labor and materials.
8. Regular Work Hours of 8 AM to 5 PM – Note that lights need to be turned on at night so this time frame will not work.
 - a. Understood. All we're saying here is that Lindquist Field is a secured facility. If work needs to be done beyond the regular hours, prior approval needs to be given and entry should be coordinated with the Project Manager.
9. Audit – Who will be conducting the audit process?
 - a. It will be performed by a third-party firm pursuant to Minor League Baseball guidelines.
10. Do you have a timeline after bid deadline?
 - a. We are anticipating the tentative schedule below:
 - i. Week of October 21st – Recommendation of Award & City Contract Routing for Approval
 - ii. Week of November 11th – Issuance of Notice to Proceed
11. Materials /Items to be removed from site – Are all items to be hauled away? Are there certain items that the City wants to keep? Or is there any special handling to preserve special items?
 - a. The City would like to retain all 15 fixtures from pole #1 (see attached map), and 10 additional fixtures from any of the remaining poles. Arrangements can be made at the time of demolition for the City to pick up fixtures from Contractor on site at Lindquist Field.
12. SITE VISIT: Is there only one service for the entire field?
 - a. There is only one service;
 - i. 400 amp with 100 amp breakers feeding each pole
 - ii. Each pole has a centrally located breaker located in the Electrical Room. Note: There are also shutoff switches located in the fuse panels on each pole.
13. CONCERN: You have aluminum wires in the feeds to each pole.
 - a. Bid the replacement of the aluminum wires from the breakers to the poles only if your particular design requires an upgrade to copper or an upgrade in sizing.
14. North East Pole - This pole is sitting on property boundary with limited access.
 - a. This needs to be accessed inside the field on the warning track.
15. Do you have manufacturer stamp information?
 - a. We only found a stamp on one pole –
 - i. Northwest Standard Corporation – 5403 W 4700 S Salt Lake City (801) 965-9532
Jacob called and confirmed that the company is still doing business. He left a message for a return call looking for any additional information on the specifics of the poles. No further information received.



Purchasing Division

16. Are we to remove the cat walk at the top of the light poles?
 - a. There are yearly maintenance requirements that necessitate access to the lighting fixtures. Provide details as to whether this access will be maintained through the use of the existing catwalk, or whether your particular design provides a catwalk or platform access point for a laborer to safely work. If your design incorporates a new platform or catwalk, the existing catwalk must be removed as part of the fixture demolition.
17. Would RFP make a provision for LED substitutions in regards to this project?
 - a. No, we are only seeking bids for LED options.
18. What are the average hours of operation per year for Lindquist Lighting?
 - a. 250 hours
19. Will you accept Active Cooling Fan Technology built into the fixtures?
 - a. Yes, if your design requires such technology to meet specified lighting standards.
20. Is it required for the bid be submitted by Lighting Manufacturer or Installing Contractor?
 - a. The City will expect a bid from the entity that will provide a turnkey system with warranty that we are seeking. This will be the main point of contact and the party responsible for executing an agreement and fulfilling all warranty issues.

- POLE LOCATIONS
- LIGHTING MEASUREMENT LOCATIONS FOR SPECTATORS

