



**ADDENDUM No. 2  
OGDEN CITY CORPORATION**

**The following changes and clarifications are hereby made to the Contract Documents for the above-referenced project:**

1. **Replace the Bid Schedule the form dated November 9, 2020.** The following changes were made:
  - a. Quantities of fence and mow strip were updated. Please note that the concrete mow strip (Bid Item 3) includes the entire length of the fence, with gates and openings, along the infield. No mow strip was included for the additional dugout fence which is within the 4" thick concrete pad.
  - b. Add Bid Item 4 – Furnish and Install 4" Thick Concrete Pad. This bid item was added for concrete in the dugouts, and the concrete work was removed from the measurement and payment for the bench. The bid item numbering was adjusted.
  - c. Measurement and Payment items were modified to include Bid Item 4 and to delete concrete work from Bid Item 5 (new numbering).
  - d. The description of Alternate Bid Item 6 was modified to clarify that this item is intended for a sidewalk.
2. **Clarification – Dugout Benches.** Benches shall be 15' surfaced mounted aluminum player's benches without backrest. Consider all plan references to be updated.
3. **Clarification – Subgrade Preparation.** All subgrade preparation for concrete mow strip, pads, and sidewalk is the responsibility of the contractor.

This Addendum is hereby attached to and made part of the Contract Documents, and each Bidder shall acknowledge receipt of this Addendum in his bid.

By: John Bjerregaard  
John Bjerregaard, P.E.

Date: November 9, 2020

**ACKNOWLEDGEMENT:**

BY: \_\_\_\_\_

(Signature)

\_\_\_\_\_  
(Contractor or Firm's Name)