


Ogden City Corporation

Invitation to Bid

Ogden Airport Terminal Expansion

Question: There are security symbols on plan sheets (E400B, E401A, E401B, E402A). I am not seeing any security specs for DIV28 – only fire alarm. Is security provided under a separate contract? Who is providing cabling and connecting to access control?



Answer: The turnstile is security equipment, not an electronic security device. Security wiring and devices are being provided and installed by Ogden City IT. The hardware conduit is by the contractor.